

CERTIFICATE

Issued to:
Applicant:
OBO Bettermann GmbH & Co.
Huingser-Ring 52
58694 Menden
Germany

Manufacturer/Licensee:
OBO Bettermann GmbH & Co.
Huingser-Ring 52
58694 Menden
Germany

Product : connecting box for fixed electrical installations
Trade name : OBO
Types : T60
 T100
 T160
 T250
 T350

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:
a type test according to the standards NEN-EN-IEC 60670-1:2005 and NEN-EN-IEC 60670-22:2007
– an inspection of the production location according to CENELEC Operational Document CIG 021
– a certification agreement with the number 900038

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.


This certificate is issued on: 28 March 2011 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2133672.01

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



H.R.M. Barends
Certification Manager

© Integral publication of this certificate is allowed

All testing, inspection, auditing and certification activities of the former KEMA Quality are an integral part of the DEKRA Certification Group.

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product	:	connecting box for fixed electrical installations
trade name	:	OBO
types	:	T60 T100 T160 T250 T350
model	:	T-series with plug-in seal
protection degree	:	IP 66
ratings	:	500 V~/16A
material	:	polypropylene
colour	:	grey RAL 7035

Product data - type T60

article number	:	2007 061
for cable cross-sections	:	up to and including 6mm ²
dimensions	:	100 x 100 x 45mm

Product data - type T100

article number	:	2007 077
for cable cross-sections	:	up to and including 10mm ²
dimensions	:	151 x 117 x 67mm

Product data - type T160

article number	:	2007 093
for cable cross-sections	:	up to and including 16mm ²
dimensions	:	180 x 150 x 77mm

Product data - type T250

article number	:	2007 109
for cable cross-sections	:	up to including 25mm ²
dimensions	:	240 x 190 x 95mm

Product data - type T350

article number	:	2007 125
for cable cross-sections	:	up to and including 35mm ²
dimensions	:	180 x 110 x 270mm

TESTS**Test requirements**


NEN-EN-IEC 60670-1:2005
NEN-EN-IEC 60670-22:2007


Test result

The test results are laid down in DEKRA test file 2133672.01.

Conclusion

The examination proved that all test requirements were met.

Tested by : R. van Daalen 

Checked by : A.A. Mackenbach 

Factory location

OBO Bettermann GmbH & Co.
Huingser-Ring 52
58694 Menden
Germany