

Technical data sheet

Underfloor test box

Item no. 5104043




- Made of concrete
- Without separating piece
- According to VDE 0185-561-5 (IEC 62561-5)

Concrete

Master data

Item no.	5104043
Type	5700 CIP SM
Description 1	Inspection pit
Description 2	without cutt-off unit
Dimension	310x310x170
Material	Concrete
Material symbol	BET
Smallest sales unit (VG)	1 Piece

Technical data



Length	325,00 mm
Length	0,35 m
Width	325,00 mm
Height	190,00 mm
Type of accessory	Test box